



10-32 THREADED INSERT

14-6 AWG SIX PLACES  
2/0 AWG THREE PLACES

INSULATED BUSBAR  
250 AMP / 600 VOLT  
NYLON BASE, ABS SNAP ON COVER  
UL & CSA 90C ALUMINUM & COPPER

<b>ALL TOLERANCES, UNLESS OTHERWISE STATED:</b> x.xxx=+/-0.005" x.xx=+/-0.01" x.x=+/-0.05"		DRAWN Robin	6/29/2014
ALL ANGLES = +/- 1° UNLESS OTHERWISE STATED		CHECKED	
MATERIAL:	STANDARDS:	QA	
FINISH:		MFG	
PROCESS:		APPROVED	

REVISION HISTORY			
REV.	DESCRIPTION OF CHANGE	DATE	SIGN

<b>MIDNITE SOLAR, INC</b>			
TITLE <b>MidNite Solar</b>			
SIZE <b>B</b>	PROJECT: MNXX	DWG NO MNTBB2-9	REV
E-FILE:mntbb2-9.iam			SHEET 1 OF 1